

SPECIFICATIONS

Leak Sealing System

Introduction

These purchase specifications cover the minimum requirements for a Leak Sealing System to be purchased by _____. This equipment is to be used by emergency personnel for sealing leaks, gashes, tears, and holes. This system will consist of the following components and accessories:

- Six Pugs
- One Brass Mallet
- One Composite Case

Instructions to Bidders

Bidders shall conform as much as possible to these specifications. Exceptions or omissions must be set out in writing on a separate sheet entitled "Exceptions" which must accompany the bid. Failure to do so will result in automatic rejection of the bid.

The buyer shall be the sole interpreter of the intent of any clause of these specifications and shall be the sole judge as to whether the equipment or any part thereof complies with the specifications.

The buyer reserves the right to reject any and all bids, to waive informalities in bidding, to negotiate small options with the successful bidder and to accept the bid, which in the opinion of the buyer, will be in its best interests.

General Construction Features

The Leak Sealing System shall adhere to the following designations and capacities:

Quantity	Designation	Dimensions
1	Long wood plug	¾ in. to 2 in. Diameter x 8 in. (0.95 cm. to 5.08 cm. Diameter x 20.32 cm.)
1	Long wood plug	1¼ in. to 3 in. Diameter x 8 in. (3.49 cm. to 7.62 cm. Diameter x 20.32 cm.)
1	Long wood plug	2¾ in. to 4 in. Diameter x 8 in. (6.03 cm. to 10.16 Diameter x 10.32 cm.)

1	Long neoprene plug	¾ in. to 2 in. Diameter x 8 in. (0.95 cm. to 5.08 cm. Diameter x 20.32 cm.)
1	Long neoprene plug	1¼ in. to 3 in. Diameter x 8 in. (3.49 cm. to 7.62 cm. Diameter x 20.32 cm.)
1	Long neoprene plug	2¾ in. to 4 in. Diameter x 8 in. (6.03 cm. to 10.16 Diameter x 10.32 cm.)
1	Brass Mallet	3 lb. (1.36 kg.)
1	Composite Case	

Long Wood Plug

The Long Wood Plugs shall consist of a tapered hardwood and be able to withstand various toxic substances.

Neoprene Plug

The Neoprene Plugs shall consist of a neoprene material and be able to withstand various toxic substances.

Brass Mallet

The Brass Mallet shall be non-sparking for additional safety in hazardous areas.

Composite Case

The Composite Case shall be designed to keep the Leak Sealing System organized.

Warranty

The seller shall be required to furnish a warranty on the complete Leak Sealing System as described in these specifications for the service intended of the buyer. All equipment furnished by the successful bidder shall be warranted against all defects in material and workmanship for a period of at least one year from date of acceptance. The seller agrees to replace, without charge, any parts shown to be defective under the terms of this warranty.

Use, Care and Maintenance Manual

Seller shall provide an illustrated step-by-step guide on the use, care and maintenance of the Leak Sealing System provided.

